

Email received on June 7, 2010 from Bob Henderson.

Alex

On page 25 of the draft, the power factor is outlined. For fluorescent, the  $\geq 0.5$  is not acceptable. It needs to be a HPF requirement on all fluorescents (including CFLs) of  $\geq 0.9$ . We know how to do this. It is just a matter of money. If we don't do this now, there will be major disruption to the electric power grid in the US when we get major saturation of CFLs. The grid is just not designed to handle such a low PF as 0.5 to 0.6.

Thanks.

*Bob Henderson, LC, CLEP*

**Progress Energy Carolinas**

**100 E. Davie St. TPP 8**

**Raleigh, NC 27601**

**Phone: 919-546-3129**

**Cell: 919-812-2076**

**E-mail: [robert.henderson@pgnmail.com](mailto:robert.henderson@pgnmail.com)**