

I would suggest that Energy Star clearly specify the use of medium surface convection/wind speed condition for calculating SRI of all roofing materials.

Allan Snyder
CertainTeed Corporation
Manager, Roofing Product Compliance