

From: "Target Windows & Doors <targetwd@sbcglobal.net>  
To: richard.karney@ee.doe.gov  
Sent: 02/18/2003 03:38 PM

Subject: Feedback on 3-zone vs 4-zone

Mr. Karney,

Regarding the email we received from Lee Bodner on 2/11/03, we would like to offer the following comments:

- 1) We would prefer the 3-zone alternative to the 4-zone, because it is less confusing for our customers.
- 2) Currently, the SHGC criteria is the same for the Central and Southern zones (0.40). We would like to see the SHGC increased from 0.40 to 0.45 for the Central zone because the Central zone is affected more with heating than the Southern zone.

Thank you very much.

Sincerely,

Dan Dickerson  
Vice-President  
Target Windows & Doors