### **Power Supply Loading Analysis** and Low-Load Testing Proposal

#### **Presented to ENERGY STAR®**

**January 24, 2018** 












# **Objectives**

- 1. Recap power supply loading concerns
- 2. Present IOU power supply loading analysis
- 3. Discuss IOU proposal for new PSU testing and reporting requirements



# A Brief History of Power Supply Loading





### What We Know Now


- PSU efficiency is key criteria to meet future efficiency specifications and regulations
- Desktop computers can idle at very low load fractions (below 10%) due to PSU sizing
- Efficiency varies widely in this load range and does not correlate to badge/rating

BUT we lack consensus on which load point(s) should be used to characterize efficiency at low load levels.




### **Estimating Desktop PSU Idle Load Fraction**

- Examined idle loading with 2 approaches:
  - Retrospective: based on ENERGY STAR measured data
  - Prospective: using CEC regulation targets
- Estimated idle load across range of desktop performance and categories
- Used power supply sizing and measured efficiency curves to iteratively arrive at load fraction estimate



# Most Systems Expected to Idle in 4-8% Range


Fraction of Desktop Configurations vs. Maximum Power Supply Load Fraction in Idle





# Future Regulations Will Push More Systems to Lower Load Points

Fraction of Desktop Configurations vs. Maximum Power Supply Load Fraction in Idle





# **IOU Power Supply Low-Load Proposal**

### **ENERGY STAR v8 Revisions**

- Measure and report following quantities at 5% and 10% load conditions:
  - $-I_{dc}, V_{dc}, P_{dc}$
  - I<sub>ac,rms</sub>, V<sub>ac,rms</sub>, P<sub>ac,true</sub>, PF, I<sub>THD</sub>

### **Long-Term Research Needs**

- Document actual idle load fraction in representative systems
- Continue to evaluate energy savings opportunities through improved PSU low-load efficiency and architecture



# **Industry Input**

 Which efficiency load points are most informative for hardware designers moving forward?

 Are there trends in system design, duty cycle, or power supply topology that we should consider?



### **ENERGY STAR Power Supply Loading Scenarios**

			Conventional Duty Cycle	Full Network Connectivity Duty Cycle
System Type	Assumed PSU Nameplate Size (W)	Assumed PSU Rating		Estimated Idle Load Fraction (%)
11	180	Gold	8%	8%
12	280	Gold	7%	7%
13	350	Gold	7%	7%
D1	460	Gold	6%	6%
D2	500	Gold	4%	4%



# **CEC Power Supply Loading Scenarios**

Tier I (2019)

Tier II (2021)

			Conventional Duty Cycle	Full Network Connectivity Duty Cycle
System Type	Assumed PSU Nameplate Size (W)	Assumed PSU Rating	Estimated Idle Load Fraction (%)	Estimated Idle Load Fraction (%)
<250 Expandability				
w/o dGfx	190	Bronze	4%	6%
w/ dGfx	250	Bronze	5%	7%
250-425 Expandability				
w/o dGfx	220	Bronze	6%	8%
w/ dGfx	250	Bronze	8%	12%
425-690 Expandabilit	У			
w/o dGfx	380	Bronze	6%	9%
w/ dGfx	500	Bronze	7%	10%
High Expandability S	ystems			
Low	750	Gold	4%	4%
High	1300	Gold	4%	4%
Workstations				
Low	210	Gold	7%	7%
High	557	Gold	17%	17%

			Conventional Duty Cycle	Full Network Connectivity Duty Cycle
	Assumed PSU		Estimated	Estimated
	Nameplate	Assumed	Idle Load	Idle Load
System Type	Size (W)	PSU Rating	Fraction (%)	Fraction (%)
<250 Expandability				
w/o dGfx	190	Bronze	4%	6%
w/ dGfx	250	Bronze	4%	6%
250-425 Expandability				
w/o dGfx	220	Bronze	5%	6%
w/ dGfx	250	Bronze	6%	8%
425-690 Expandabilit	у			
w/o dGfx	380	Bronze	5%	7%
w/ dGfx	500	Bronze	5%	7%
High Expandability Systems				
Low	750	Gold	4%	4%
High	1300	Gold	4%	4%
Workstations	0			
Low	210	Gold	7%	7%
High	557	Gold	17%	17%

