



ENERGY STAR Certified Homes, Version 3.1 (Rev. 01) HERS Index Target Procedure for Massachusetts Program Requirements

This document provides detailed instructions for determining the ENERGY STAR HERS Index Target, the highest HERS Index value that a home can achieve and be certified under the Performance Path of the program. The Performance Path provides flexibility to select a custom combination of measures through energy modeling that achieves the required ENERGY STAR HERS Index Target. Note, however, that regardless of the measures selected, the Mandatory Requirements for All Certified Homes in Exhibit 2 of the ENERGY STAR Certified Homes Version 3.1 (Rev. 01) Program Requirements for Massachusetts shall be met.

Follow these steps using any RESNET-accredited software program to calculate the ENERGY STAR HERS Index Target:

1. Determine the HERS Index of the ENERGY STAR Reference Design Home for Massachusetts. To accomplish this, use Exhibit 2 below, Expanded ENERGY STAR Reference Design Definition for Massachusetts, to model the Reference Design Home and determine its associated HERS Index value. For Raters configuring the ENERGY STAR Reference Design manually, EPA provides the following guidance:
 - a. The ENERGY STAR Reference Design Home is virtually identical to the home that would have been built using the minimum requirements of the Prescriptive Path. Therefore, EPA suggests that Raters complete a plan take-off of the home to be built, configure it with the minimum requirements of the Prescriptive Path, and then review Exhibit 2 of this document for any remaining items that need to be changed.
 - b. Any item in Exhibit 2 that states “Same as Rated Home” means that the parameter should be identical to the Rated Home. Therefore, if the Rater follows the guidance in item a), these parameters don’t need to be further adjusted when calculating the ENERGY STAR HERS Index Target.
 - c. RESNET requires that all accredited software automatically configure certain parameters when calculating a HERS index value (e.g., internal gains, thermostat setpoints, water heater temp.). Any item in Exhibit 2 that begins with a plus (+) and is shaded gray will be automatically configured by the software, indicating that the Rater need not do anything to comply with these items when calculating the HERS Index Target.
 - d. In Exhibit 2, slab insulation R-values represent nominal insulation levels; U-factors and SHGC coefficients for windows and doors apply to the entire assembly; and assembly U-factors for foundations, floors, walls, and ceilings represent the overall U-value of the assembly, inclusive of exterior sheathing materials, cavity insulation and installation quality, framing, and interior finishes. To create an assembly that meets the required U-factor, Raters may wish to start with the nominal insulation R-values indicated in the county-level Reference Design applicable to the Rated Home, and then modify the assembly details until the U-factor aligns.
2. For all single-family detached homes, townhomes, rowhomes, duplexes, triplexes, and quadplexes, calculate the Size Adjustment Factor (SAF) using the following equation:

$$SAF = [CFA_{\text{Benchmark Home}} / CFA_{\text{Home To Be Built}}]^{0.25}, \text{ not to exceed } 1.0$$

Where:

$CFA_{\text{Benchmark Home}}$ = Conditioned Floor Area of the Benchmark Home, using Exhibit 1 below

$CFA_{\text{Home to be Built}}$ = Conditioned Floor Area of the Home to be Built

For the purposes of this step, calculate the number of bedrooms and the CFA of the home to be built using RESNET standards with the following exception: floor area in basements with at least half of the gross surface area of the basement’s exterior walls below grade shall not be counted.¹ If the CFA of the home to be built exceeds the CFA of the Benchmark Home, then the Performance Path shall be used. Because the SAF cannot exceed 1.0, it only modifies the HERS Index Target for homes with conditioned floor area greater than the Benchmark Home. For condos and apartments in multi-family buildings the SAF shall always equal 1.0.

3. Calculate the ENERGY STAR HERS Index Target, rounded to the nearest whole number:

$$\text{ENERGY STAR HERS Index Target} = \text{HERS Index of ENERGY STAR Reference Design Home} \times \text{SAF}$$
4. Next, proceed with Step 2 of the Performance Path as outlined in the ENERGY STAR Certified Homes Version 3.1 (Rev. 01) Program Requirements for Massachusetts

Exhibit 1: Benchmark Home Size^{2,3}

Bedrooms in Home to be Built	0	1	2	3	4	5	6	7	8
Conditioned Floor Area <small>Benchmark Home</small>	1,000	1,000	1,600	2,200	2,800	3,400	4,000	4,600	5,200



ENERGY STAR Certified Homes, Version 3.1 (Rev. 01) HERS Index Target Procedure for Massachusetts Program Requirements

Exhibit 2: Expanded ENERGY STAR Reference Design Definition for Massachusetts (Continued)

Heating Systems:	Heating loads may be calculated and equipment capacity selected according to the latest edition of ACCA Manual J, ASHRAE 2009 Handbook of Fundamentals, or a substantively equivalent procedure; otherwise, same as Rated Home.																																										
	Fuel Type: Same as Rated Home ¹⁰																																										
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump where Rated Home is modeled with ground-source heat pump, electric strip or baseboard heat; applicable efficiency selected from below																																										
	Climate Zone: Massachusetts																																										
	Gas Furnace AFUE: 95 Oil Furnace AFUE: 85 Gas Boiler AFUE: 90 Oil Boiler AFUE: 86 Air-Source Heat Pump HSPF: 9.5 Air-Source Heat Pump Backup: Electric																																										
Cooling Systems:	Cooling loads may be calculated and equipment capacity selected according to the latest edition of ACCA Manual J, ASHRAE 2009 Handbook of Fundamentals, or a substantively equivalent procedure; otherwise, same as Rated Home.																																										
	Fuel Type: Same as Rated Home ¹⁰																																										
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump where Rated Home is modeled with ground-source heat pump; applicable efficiency selected from below.																																										
	Climate Zone: Massachusetts																																										
	AC SEER: 13.0 Air-Source Heat Pump SEER: 16																																										
Service Water Heating Systems:	+ Use (Gallons per Day): Same as HERS Reference Home, as defined by RESNET's standard. ⁹																																										
	+ Tank Temperature: Same as HERS Reference Home, as defined by RESNET's standard. ⁹																																										
	Fuel Type: Same as Rated Home ¹⁰																																										
	System Type: Conventional storage water heater with tank size equal to that of Rated Home, unless Rated Home uses instantaneous water heater, in which case select 40 gallon tank for gas systems and 60 gallon tank for electric systems. Select applicable efficiency from below using tank size of Reference Home.																																										
	<table border="1"> <tr> <td>Gas Storage Tank Capacity:¹¹</td> <td>30 Gallon</td> <td>40 Gallon</td> <td>50 Gallon</td> <td>60 Gallon</td> <td>70 Gallon</td> <td>80 Gallon</td> </tr> <tr> <td>Gas DHW EF:</td> <td>0.63</td> <td>0.61</td> <td>0.59</td> <td>0.57</td> <td>0.55</td> <td>0.53</td> </tr> <tr> <td>Electric Storage Tank Capacity:¹¹</td> <td>30 Gallon</td> <td>40 Gallon</td> <td>50 Gallon</td> <td>60 Gallon</td> <td>70 Gallon</td> <td>80 Gallon</td> </tr> <tr> <td>Electric DHW EF:</td> <td>0.94</td> <td>0.93</td> <td>0.92</td> <td>0.91</td> <td>0.90</td> <td>0.89</td> </tr> <tr> <td>Oil Storage Tank Capacity:¹¹</td> <td>30 Gallon</td> <td>40 Gallon</td> <td>50 Gallon</td> <td>60 Gallon</td> <td>70 Gallon</td> <td>80 Gallon</td> </tr> <tr> <td>Oil DHW EF:</td> <td>0.55</td> <td>0.53</td> <td>0.51</td> <td>0.49</td> <td>0.47</td> <td>0.45</td> </tr> </table>	Gas Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon	Gas DHW EF:	0.63	0.61	0.59	0.57	0.55	0.53	Electric Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon	Electric DHW EF:	0.94	0.93	0.92	0.91	0.90	0.89	Oil Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon	Oil DHW EF:	0.55	0.53	0.51	0.49	0.47	0.45
	Gas Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon																																				
	Gas DHW EF:	0.63	0.61	0.59	0.57	0.55	0.53																																				
	Electric Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon																																				
Electric DHW EF:	0.94	0.93	0.92	0.91	0.90	0.89																																					
Oil Storage Tank Capacity: ¹¹	30 Gallon	40 Gallon	50 Gallon	60 Gallon	70 Gallon	80 Gallon																																					
Oil DHW EF:	0.55	0.53	0.51	0.49	0.47	0.45																																					
Thermal Distribution Systems:	Duct Leakage to Outside: None (all ducts in conditioned space)																																										
	Duct Insulation: • R-8 on supply ducts located in unconditioned attic • R-6 on all other ducts located in unconditioned spaces																																										
	Duct Surface Area: Same as Rated Home																																										
	Supply and Return Duct Locations:																																										
	<table border="1"> <tr> <td>Foundation Type:</td> <td>Slab</td> <td>Crawlspace</td> <td>Basement</td> </tr> <tr> <td>One Story:</td> <td>100% Conditioned</td> <td>100% Conditioned</td> <td>100% Conditioned</td> </tr> <tr> <td>Two Story:</td> <td>100% Conditioned</td> <td>100% Conditioned</td> <td>100% Conditioned</td> </tr> </table>	Foundation Type:	Slab	Crawlspace	Basement	One Story:	100% Conditioned	100% Conditioned	100% Conditioned	Two Story:	100% Conditioned	100% Conditioned	100% Conditioned																														
Foundation Type:	Slab	Crawlspace	Basement																																								
One Story:	100% Conditioned	100% Conditioned	100% Conditioned																																								
Two Story:	100% Conditioned	100% Conditioned	100% Conditioned																																								
Thermostat:	Type: Programmable																																										
	+ Temperature Setpoints: Same as HERS Reference Home, with offsets defined by RESNET's standard, ⁹ Section 303.5.1.2																																										
Infiltration & Mechanical Ventilation:	Infiltration Rates:																																										
	Climate Zone: Massachusetts																																										
	ACH50: 2																																										
	Mechanical Ventilation with Heat Recovery																																										
	Rate: CFM = 0.01 * CFA + 7.5 * (Nbr + 1), where CFA = Conditioned Floor Area and Nbr = Number of Bedrooms																																										
	Hours per Day: 24																																										
	Fan Watts: Watts = CFM Rate / 2.2 CFM per Watt, where CFM Rate is determined above																																										
	<table border="1"> <tr> <td>Climate Zone: Massachusetts</td> </tr> <tr> <td>Ventilation Type: Balanced</td> </tr> <tr> <td>Sensible Recovery Efficiency: 55%</td> </tr> <tr> <td>Total Recovery Efficiency: 0%</td> </tr> </table>	Climate Zone: Massachusetts	Ventilation Type: Balanced	Sensible Recovery Efficiency: 55%	Total Recovery Efficiency: 0%																																						
Climate Zone: Massachusetts																																											
Ventilation Type: Balanced																																											
Sensible Recovery Efficiency: 55%																																											
Total Recovery Efficiency: 0%																																											
Lighting, Appliances, & Internal Gains:	Fluorescent Lighting: 90%																																										
	Refrigerator: 423 kWh per year																																										
	Dishwasher: 0.66 EF																																										
	Ceiling Fan: 122 CFM per Watt																																										
	+ Internal Gains: Defined by Section 303.5.1.1 of RESNET's standard ⁹ and adjusted for internal gains from the high-efficiency lighting and appliances listed above, as provided by Section 303.4.1.7.																																										
Internal Mass:	+ Same as HERS Reference Home, as defined by RESNET's standard. ⁹																																										
	Additional mass specifically designed as a Thermal Storage Element for the Rated Home shall be excluded.																																										



ENERGY STAR Certified Homes, Version 3.1 (Rev. 01) HERS Index Target Procedure for Massachusetts Program Requirements

1. To determine whether at least half of the basement wall area is below grade, use the gross surface area of the walls that are in contact with either the ground or ambient outdoor air, measured from the basement floor to the bottom of the basement ceiling framing (e.g., the bottom of the joists for the floor above). Note that the exception regarding the floor area in basements is only for the purpose of determining a home's Benchmark Home Size, Size Adjustment Factor, and eligibility to use the Prescriptive Path. The full conditioned floor area, per RESNET's standards, should be used when rating the home (e.g., determining compliance with duct leakage requirements).

2. The average-size home with a specific number of bedrooms is termed the "Benchmark Home". A bedroom is defined by RESNET as a room or space 70 sq. ft. or greater size, with egress window and closet, used or intended to be used for sleeping. A "den", "library", or "home office" with a closet, egress window, and 70 sq. ft. or greater size or other similar rooms shall count as a bedroom, but living rooms and foyers shall not.

An egress window, as defined in 2009 IRC section R310, shall refer to any operable window that provides for a means of escape and access for rescue in the event of an emergency. The egress window definition has been summarized for convenience. The egress window shall:

- have a sill height of not more than 44 in. above the floor; AND
- have a minimum net clear opening of 5.7 sq. ft.; AND
- have a minimum net clear opening height of 24 in.; AND
- have a minimum net clear opening width of 20 in.; AND
- be operational from the inside of the room without the use of keys, tools or special knowledge.

3. The conditioned floor area of a Benchmark Home (CFA Benchmark Home) is determined by selecting the appropriate value from Exhibit 1. For homes with more than 8 bedrooms, the CFA Benchmark Home shall be determined by multiplying 600 sq. ft. times the total number of bedrooms and adding 400 sq. ft.

Example: CFA Benchmark Home for a 10 bedroom home = (600 sq. ft. x 10) + 400 sq. ft. = 6,400 sq. ft.

4. The Rater may define the 'permit date' as either the date that the permit was issued or the date of the contract on the home. In cases where permit or contract dates are not available, Providers have discretion to estimate permit dates based on other construction schedule factors. These assumptions should be both defensible and documented.

5. Any parameter not specified in this exhibit shall be set to "Same as Rated Home".

6. For informative purposes, assembly U-factors are meant to correlate to typical assemblies containing the nominal R-values as listed in 2012 IECC Table R402.1.3.

7. All Reference Design window and door U-value and SHGC requirements are based on the ENERGY STAR Program Requirements for Residential Windows, Doors, and Skylights – Version 5.0 as outlined at www.energystar.gov/windows, except that SHGC values have been assumed for CZ 4 C & 5-8. Note that the U-factor requirement applies to all fenestration while the SHGC only applies to the glazed portion.

8. When determining the ENERGY STAR HERS Index Target for homes with conditioned basements & for attached homes under the Performance Path, the following formula shall be used to determine total window area of the ENERGY STAR Reference Design:

$$AF = 0.15 \times AFL \times FA \times F$$

Where:

- AF = Total fenestration area
- AFL = Total floor area of directly conditioned space
- FA = (Above-grade thermal boundary gross wall area) / (Above-grade boundary wall area + 0.5 x Below-grade boundary wall area)
- F = 1 - 0.44 x (Common wall area) / (Above-grade thermal boundary wall area + Common wall area)

And where:

- Thermal boundary wall is any wall that separates directly or indirectly conditioned space from unconditioned space or ambient conditions;
- Above-grade thermal boundary wall is any portion of a thermal boundary wall not in contact with soil;
- Below-grade boundary wall is any portion of a thermal boundary wall in soil contact; and
- Common wall is the total wall area of walls adjacent to another conditioned living unit, not including foundation walls.

9. RESNET's 2006 Mortgage Industry National Home Energy Rating Systems Standard.

10. In the ENERGY STAR Reference Design, fuel type(s) shall be same as Rated Home, including any dual-fuel equipment where applicable. For a Rated Home with multiple heating, cooling, or water heating systems using different fuel types, the applicable system capacities and fuel types shall be weighted in accordance with the loads distribution (as calculated by accepted engineering practice for that equipment and fuel type) of the multiple systems.

11. To determine domestic hot water (DHW) EF requirements for additional tank sizes, use the following equations: Gas DHW EF \geq 0.69 - (0.002 x Tank Gallon Capacity); Electric DHW EF \geq 0.97 - (0.001 x Tank Gallon Capacity); Oil DHW EF \geq 0.61 - (0.002 x Tank Gallon Capacity).