

It is a big step backwards in our goal of sustainability to prevent passive solar heating. Consequently, there should be no maximum SHGC for any window facing south or 30 degrees from south. It is not unreasonable for the glazing to be different on south and other facades. Although industry may prefer only one type of glazing per building, reality requires at least two types in many cases. The benefits of passive solar heating are immense and must not be prevented.

Feel free to contact me if you like.

Norbert

Norbert Lechner, Prof. Emeritus & Architect

Auburn University
719 Mercer Circle
Auburn, AL 36830
