

Hoffmeyer, Darcy

From: Addlightinfo@aol.com
Sent: Friday, February 07, 2003 11:39 AM
To: Hoffmeyer, Darcy
Subject: Version 3.0 comments

Comments to Darcy Hoffmeyer, dhoffmeyer@icfconsulting.com
Subject: EPA Draft 2, Version 3.0 ENERGY STAR for Exit Signs.

As a supplier of electric and photoluminescent Exit Signs, we assess Version 3.0 to be much improved and presenting a realistic program for achieving Energy Star status for all types of Exit signs.

The maximum input power demand of 3 watts for electric signs is a good limit and within the range of available technology. You are right to maintain this limit to lead the change to more efficient Exit signs.

Congratulations for the careful review of comments to the previous version and developing a clearer and fairer standard to meet EPA goals of reduced power consumption.

Sincerely,

Paul R. Holmes
President
AddLight
Charlotte, NC
PHONE 704-525-6210