

# ENERGY STAR<sup>®</sup>

## Residential New Construction Programs

### Historical Document

This document is provided for reference because it has been superseded by a more recent Version or Revision. Please find current program documents on the [Program Requirements](#) webpage.

Use of older Versions and Revisions, such as this document, are typically limited to homes and buildings with a permit date (or, for manufactured homes, a production date) prior to a specified date. Consult the [Implementation Timeline](#) table to assess whether a home or apartment is still eligible to be certified using this document.

For questions or more information, contact us at [energystarhome@energystar.gov](mailto:energystarhome@energystar.gov).



# ENERGY STAR Single-Family New Homes

## Caribbean & Pacific Rater Field Checklist, Version 3 / 3.2 (Rev. 13)

Requirements specific to the "Caribbean" shall be met in Puerto Rico and the U.S Virgin Islands. Requirements specific to the "Pacific" shall be met in Guam, Hawaii, and the Northern Mariana Islands.						
Home Address: _____		City: _____		State: _____		Permit Date: _____
HVAC System <sup>1</sup> (National HVAC Design Report Item # indicated in parenthesis)				Must Correct	Rater Verified <sup>2</sup>	N/A <sup>3</sup>
<b>1. Duct Quality Installation</b> - Applies to Heating, Cooling, Ventilation, Exhaust, & Pressure Balancing Ducts, Unless Noted in Footnote						
1.1 Ductwork installed without kinks, sharp bends, compressions, or excessive coiled flexible ductwork. <sup>4</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.2 All supply and return ducts in unconditioned space, including connections to trunk ducts, are insulated to $\geq R-6$ <sup>5</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>2. Dwelling Unit Mechanical Ventilation Systems ("Vent System") <sup>6</sup> &amp; Inlets in Return Duct <sup>7</sup></b>						
2.1 Rater-measured ventilation rate is within either $\pm 15$ CFM or $\pm 15\%$ of design value (2.3). <sup>8</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.2 A readily-accessible ventilation override control installed and also labeled if its function is not obvious (e.g., a label is required for a toggle wall switch, but not for a switch that's on the ventilation equipment). <sup>9</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.3 For any outdoor air inlet connected to a ducted return of the HVAC system (Complete if present; otherwise check "N/A"): <sup>7</sup>						<input type="checkbox"/>
2.3.1 Controls automatically restrict airflow using a motorized damper during vent. off-cycle and occupant override. <sup>10</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.3.2 Rater-measured vent. rate is $\leq 15$ CFM or 15% above design value at highest HVAC fan speed. Alt. in Fn. 11. <sup>11</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.4 System fan rated $\leq 3$ sones if intermittent and $\leq 1$ sone if continuous, or exempted. <sup>12</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.5 If Vent System controller operates the HVAC fan, then HVAC fan operation is intermittent and either the fan type is ECM / ICM (4.7) or the controls will reduce the run-time by accounting for HVAC system heating or cooling hours. <sup>13</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.6 Bathroom fans are ENERGY STAR certified if used as part of the Vent System. <sup>14</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.7 Air inlet location (Complete if ventilation air inlet location was specified (2.12, 2.13); otherwise check "N/A"): <sup>15, 16</sup>				-	-	<input type="checkbox"/>
2.7.1 Inlet pulls ventilation air directly from outdoors and not from attic, crawlspace, garage, or adjacent dwelling unit.				<input type="checkbox"/>	<input type="checkbox"/>	-
2.7.2 Inlet is $\geq 2$ ft. above grade or roof deck; $\geq 10$ ft. of stretched-string distance from known contamination sources not exiting the roof, and $\geq 3$ ft. distance from dryer exhausts and sources exiting the roof. <sup>17</sup>				<input type="checkbox"/>	<input type="checkbox"/>	-
2.7.3 Inlet is provided with rodent / insect screen with $\leq 0.5$ inch mesh.				<input type="checkbox"/>	<input type="checkbox"/>	-
<b>3. Local Mechanical Exhaust</b> - In each kitchen and bathroom, a system is installed that exhausts directly to the outdoors and meets one of the following Rater-measured airflow and manufacturer-rated sound level standards: <sup>8, 18</sup>						
Location		Continuous Rate		Intermittent Rate <sup>19</sup>		
3.1 Kitchen	Airflow	$\geq 5$ ACH, based on kitchen volume <sup>20, 21</sup>		$\geq 100$ CFM and, if not integrated with range, also $\geq 5$ ACH based on kitchen volume <sup>20, 21, 22</sup>		
	Sound	Recommended: $\leq 1$ sone		Recommended: $\leq 3$ sones		
3.2 Bathroom <sup>23</sup>	Airflow	$\geq 20$ CFM		$\geq 50$ CFM		
	Sound	Required: $\leq 1$ sone		Recommended: $\leq 3$ sones		
<b>4. Combustion Appliances</b>						
4.1 Furnaces, boilers, & water heaters are mechanically drafted or direct-vented. Alternatives in Footnote 26. <sup>24, 25, 26</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2 Fireplaces are mechanically drafted or direct-vented. Alternatives in Footnote 27. <sup>24, 25, 27</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3 No unvented combustion appliances other than cooking ranges or ovens are located inside the home's pressure boundary. Alternative in Footnote 28. <sup>24, 28, 29</sup>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>5. Thermal Comfort System</b>						
5.1 Operable apertures provided that meet the specifications of the Caribbean & Pacific Rater Design Review Checklist as follows:						
5.1.1 Area, placement, & function is as specified in Items 4.1.1 through 4.1.3.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.1.2 Wing walls present if specified in Item 4.1.3.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.1.3 Insect screens provided per specifications in Item 4.1.4.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.1.4 Integral devices capable of holding components open provided per specifications in Item 4.1.5.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.1.5 Mechanically-attached door stop or similar device provided per specifications in Item 4.1.6.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.2 Ceiling fans (i.e., not just a junction box) installed per specifications in Item 4.2.				<input type="checkbox"/>	<input type="checkbox"/>	-
5.3 Wall insulation meets or exceeds R-5.				<input type="checkbox"/>	<input type="checkbox"/>	-
This Item only required for homes in the Pacific, otherwise check "N/A".						<input type="checkbox"/>
5.4a Solar gain through windows reduced per specifications in Item 4.4a.				<input type="checkbox"/>	<input type="checkbox"/>	-
This Item only required for homes in the Caribbean, otherwise check "N/A".						<input type="checkbox"/>
5.4b Solar gain through windows reduced per specifications in Item 4.4b.				<input type="checkbox"/>	<input type="checkbox"/>	-



# ENERGY STAR Single-Family New Homes

## Caribbean & Pacific Rater Field Checklist, Version 3 / 3.2 (Rev. 13)

6. Air Sealing (Unless otherwise noted below, "sealed" indicates the use of caulk, foam, or equivalent material)	Must Correct	Rater Verified <sup>2</sup>	N/A <sup>3</sup>
6.1 Ducts, flues, shafts, plumbing, piping, wiring, exhaust fans, & other penetrations to unconditioned space sealed, with blocking / flashing as needed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.2 Rough opening around windows & exterior doors sealed. <sup>30</sup>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.3 Walls that separate attached garages from occupiable space sealed and, also, an air barrier installed and sealed at floor cavities aligned with these walls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.4 Doors adjacent to unconditioned space (e.g., attics, garages, basements, unconditioned living space) or ambient conditions made substantially air-tight with weatherstripping or equivalent gasket.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>7. Solar Water Heating System</b>			
7.1 System is Solar Rating & Certification Corporation OG-300 certified. <sup>31</sup>	<input type="checkbox"/>	<input type="checkbox"/>	-
Only required for homes in the Pacific, otherwise check "N/A".			<input type="checkbox"/>
7.2a System has a Solar Fraction $\geq 90\%$ . If system was rated without a backup water heater, then backup water has not been installed. <sup>31</sup>	<input type="checkbox"/>	<input type="checkbox"/>	-
Only required for homes in the Caribbean, otherwise check "N/A".			<input type="checkbox"/>
7.2b If system is installed to comply with Measure A of the Caribbean Program Requirements, it has a Solar Fraction $\geq 87\%$ . If system was rated without a backup water heater, then backup water has not been installed. <sup>31</sup>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>8. Mini-Split HVAC System</b>			
Only required for homes in the Pacific, otherwise check "N/A".			<input type="checkbox"/>
8.1a Mini-split AC's or HP's $\geq 16$ SEER or SEER2, each with $\leq 10$ ft. of ductwork, serve all bedrooms. <sup>32</sup>	<input type="checkbox"/>	<input type="checkbox"/>	-
8.2a No space cooling is required outside of bedrooms, but if any space cooling is provided outside bedrooms, it is provided using mini-split AC's or HP's $\geq 16$ SEER or SEER2, each with $\leq 10$ ft. of ductwork.	<input type="checkbox"/>	<input type="checkbox"/>	-
Only required for homes in the Caribbean, otherwise check "N/A".			<input type="checkbox"/>
8.1b If mini-split AC's or HP's are used to comply with Measure B of the Caribbean Program Requirements, they are $\geq 15$ SEER or SEER2, each with $\leq 10$ ft. of ductwork, and serve all bedrooms. <sup>32</sup>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.2b No space cooling is required outside of bedrooms, but if any space cooling is provided outside bedrooms, it is provided using mini-split AC's or HP's $\geq 15$ SEER or SEER2, each with $\leq 10$ ft. of ductwork.	<input type="checkbox"/>	<input type="checkbox"/>	-
8.3b If a mini-split HVAC system will <u>not</u> be installed in the bedrooms at the time of certification, then the following details shall be included so that a mini-split HVAC system may be installed more easily after certification. If a mini-split HVAC system will be installed at the time of certification, then check "N/A".			<input type="checkbox"/>
8.3.1b A wall-mounted junction box installed at code height within the designated area for the condensing unit along with electrical conduit from the junction box to the main electric panel board for the dwelling.	<input type="checkbox"/>	<input type="checkbox"/>	-
8.3.2b A 3" pipe sleeve installed through the exterior wall, for future power, communication, and refrigerant line connections between the area designated for the condensing unit and fan-coil units.	<input type="checkbox"/>	<input type="checkbox"/>	-
8.3.3b If the designated location of the wall-mounted mini-split fan-coil units is on an interior wall, then a 1" condensate drain line installed with a point of connection at the fan-coil units and that terminates in storm water lines or outdoors, and insulated with 1/2" thick elastomeric or equivalent insulation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>9. LED Lighting</b>			
9.1 LED light bulbs installed in 100% of ANSI / RESNET / ICC 301-defined Qualifying Light Fixture Locations.	<input type="checkbox"/>	<input type="checkbox"/>	-
Rater Name: _____ Rater Pre-Drywall Inspection Date <sup>33</sup> : _____ Rater Initials: _____			
Rater Name: _____ Rater Final Inspection Date <sup>34</sup> : _____ Rater Initials: _____			



# ENERGY STAR Single-Family New Homes Caribbean & Pacific Rater Field Checklist, Version 3 / 3.2 (Rev. 13)

## Footnotes

1. This Checklist is designed to meet ASHRAE 62.2-2010 or later, and ANSI / ACCA's 5 QI-2015 protocol, thereby improving the performance of HVAC equipment in new homes when compared to homes built to minimum code. However, these features alone cannot prevent all ventilation, indoor air quality, and HVAC problems, (e.g., those caused by a lack of maintenance by occupants). Therefore, this Checklist is not a guarantee of proper ventilation, indoor air quality, or HVAC performance.
2. All items shall be verified for each certified home and sampling protocols shall not be used. The term 'Rater' refers to the person(s) completing the third-party verification required for certification. The person(s) shall: a) be a Certified Rater or Approved Inspector, as defined by ANSI / RESNET / ICC 301, or an equivalent designation as determined by a Home Certification Organization (HCO); and, b) have attended and successfully completed an EPA-recognized training class. See [www.energystar.gov/newhomestraining](http://www.energystar.gov/newhomestraining).
3. The column titled "N/A," which denotes items that are "not applicable," should be used when the checklist item or sub-section is not applicable to the region where the home is being certified, is not present in the home, or conflicts with local requirements.
4. Kinks are to be avoided and are caused when ducts are bent across sharp corners such as framing members. Sharp bends are to be avoided and occur when the radius of the turn in the duct is less than one duct diameter. Compression is to be avoided and occurs when flexible ducts in unconditioned space are installed in cavities smaller than the outer duct diameter and ducts in conditioned space are installed in cavities smaller than inner duct diameter. Ducts shall not include coils or loops except to the extent needed for acoustical control.
5. Item 1.2 does not apply to ducts that are a part of local mechanical exhaust and exhaust-only dwelling unit mechanical ventilation systems. EPA recommends, but does not require, that all metal ductwork not encompassed by Section 1 (e.g., exhaust ducts, duct boots, ducts in conditioned space) also be insulated and that insulation be sealed to duct boots to prevent condensation.
6. As defined by ANSI / RESNET / ICC 301-2019, a Dwelling Unit Mechanical Ventilation System is a ventilation system consisting of powered ventilation equipment such as motor-driven fans and blowers and related mechanical components such as ducts, inlets, dampers, filters and associated control devices that provides dwelling-unit ventilation at a known or measured airflow rate.
7. Item 2.3 applies to any outdoor air inlet connected to a ducted return of the dwelling unit HVAC system, regardless of its intended purpose (e.g., for ventilation air, make-up air, combustion air). This item does not apply to HVAC systems without a ducted return.
8. The Dwelling Unit Mechanical Ventilation System air flows and local exhaust air flows shall be determined and documented by a Rater using ANSI / RESNET / ICC 380 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the HCO that the home is being certified under. Designers are permitted to provide multiple combinations of a design ventilation airflow rate, run-time per cycle, and cycle time. When multiple combinations are provided, the Rater shall first assess the run-time setting of the installed system and use that to determine the corresponding design ventilation rate. The Rater-measured ventilation rate must fall within the program-specified tolerance relative to that design ventilation rate.
9. For an attached dwelling unit, excluding units in dwellings (i.e., duplex) and townhomes, the override control is not required to be readily accessible to the occupant. However, in such cases, EPA recommends but does not require that the control be readily accessible to others (e.g., building maintenance staff) in lieu of the occupant.
10. For example, if an outdoor air inlet connected to a ducted return is used as a dedicated source of outdoor air for an exhaust ventilation system (e.g., bath fan), the outdoor airflow must be automatically restricted when the exhaust fan is not running and in the event of an override of the exhaust ventilation system.
11. When assessing the ventilation rate, the highest HVAC fan speed applicable to ventilation mode shall be used (e.g., if the inlet only opens when the HVAC is in 'fan-only' mode, then test in this mode). If the inlet has a motorized damper that only opens when the local mechanical kitchen exhaust is turned on, then testing is not required.  
When required, the ventilation airflow through the inlet shall be measured and documented by a Rater using ANSI / RESNET / ICC 380 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the HCO that the home is being certified under. As an alternative, measurement of the outdoor airflow can be waived if a Constant Airflow Regulating (CAR) damper with a manufacturer-specified maximum flow rate no higher than 15 CFM or 15% above the ventilation design value is installed on the inlet.
12. Dwelling Unit Mechanical Ventilation System fans shall be rated for sound at no less than the airflow rate in Item 2.3 of the National HVAC Design Report. Fans exempted from this requirement include HVAC air handler fans, remote-mounted fans, and intermittent fans rated  $\geq$  400 CFM. To be considered for this exemption, a remote-mounted fan must be mounted outside the habitable spaces, bathrooms, toilets, and hallways and there shall be  $\geq$  4 ft. ductwork between the fan and intake grill. Per ASHRAE 62.2-2010, habitable spaces are intended for continual human occupancy; such space generally includes areas used for living, sleeping, dining, and cooking but does not generally include bathrooms, toilets, hallways, storage areas, closets, or utility rooms.
13. Note that the 'fan-on' setting of a thermostat would not be an acceptable controller because it would continuously operate the HVAC fan.
14. Bathroom fans with a rated flow rate  $\geq$  500 CFM are exempted from the requirement to be ENERGY STAR certified.
15. Without proper maintenance, ventilation air inlet screens often become filled with debris. Therefore, EPA recommends, but does not require, that these ventilation air inlets be located so as to facilitate access and regular service by the occupant. Ventilation air inlets that are only visible via rooftop access are exempted from Item 2.7 and the Rater shall mark "N/A".
16. Two alternatives to the required 10 ft. distance are provided: 1) inlets providing outdoor air to a dwelling unit are permitted to be  $\geq$  5 ft. of stretched-string distance from outlets of both exhaust dwelling unit mechanical ventilation systems and local mechanical exhaust systems, and 2) the outlet and inlet of ERV's and HRV's may use a smaller distance if allowed by the manufacturer of the system. If the second alternative is used, the manufacturer's instructions shall be collected for documentation purposes.
17. Known contamination sources include, but are not limited to, stacks, vents, exhausts, and vehicles.
18. Continuous bathroom local mechanical exhaust fans shall be rated for sound at no less than the airflow rate in Item 3.2. Intermittent bathroom and both intermittent and continuous kitchen local mechanical exhaust fans are recommended, but not required, to be rated for sound at no less than the airflow rate in Items 3.1 and 3.2. Per ASHRAE 62.2-2010, an exhaust system is one or more fans that remove air from the building, causing outdoor air to enter by ventilation inlets or normal leakage paths through the building envelope (e.g., bath exhaust fans,



# ENERGY STAR Single-Family New Homes

## Caribbean & Pacific Rater Field Checklist, Version 3 / 3.2 (Rev. 13)

range hoods, clothes dryers). Per ASHRAE 62.2-2010, a bathroom is any room containing a bathtub, shower, spa, or similar source of moisture.

19. An intermittent mechanical exhaust system, where provided, shall be designed to operate as needed by the occupant. Control devices shall not impede occupant control in intermittent systems.
20. Kitchen volume shall be determined by drawing the smallest possible rectangle on the floor plan that encompasses all cabinets, pantries, islands, peninsulas, ranges / ovens, and the kitchen exhaust fan, and multiplying by the average ceiling height for this area. In addition, the continuous kitchen exhaust rate shall be  $\geq 25$  CFM, per 2009 IRC Table M1507.3, regardless of the rate calculated using the kitchen volume. Cabinet volume shall be included in the kitchen volume.
21. Homes shall meet this Item. Alternatively, the prescriptive duct sizing requirements in Table 5.3 of ASHRAE 62.2-2010 or later are permitted to be used for kitchen exhaust fans based upon the rated airflow of the fan at 0.25 IWC. If the rated airflow is unknown,  $\geq 6$  in. smooth duct shall be used, with a rectangular to round duct transition as needed. Guidance to assist partners with these alternatives is available at <http://www.energystar.gov/newhomesguidance>. As an alternative to Item 3.1, homes are permitted to use a continuous kitchen exhaust rate of 25 CFM per 2009 IRC Table M1507.3, if they are either a) Phius or PHI certified or b) provide both dwelling unit ventilation and local mechanical kitchen exhaust using a balanced system, and have a Rater-verified whole-building infiltration rate  $\leq 1.0$  ACH50 or  $\leq 0.05$  CFM50 per sq. ft. of Enclosure Area, and a Rater-verified dwelling unit compartmentalization rate  $\leq 0.30$  CFM50 per sq. ft. of Enclosure Area if multiple dwelling units are present in the building. 'Enclosure Area' is defined as the area of the surfaces that bound the volume being pressurized / depressurized during the test.
22. All intermittent kitchen exhaust fans must be capable of exhausting at least 100 CFM. In addition, if the fan is not part of a vented range hood or appliance-range hood combination (i.e., if the fan is not integrated with the range), then it must also be capable of exhausting  $\geq 5$  ACH, based on the kitchen volume.
23. For dwellings and dwelling units in the Caribbean, a local mechanical exhaust fan is not required in a bathroom that has operable window area totaling a minimum of 12% of the floor area specified for that bathroom. Components contributing to the operable window area must be able to be opened without the use of ladders or special tools. Operable area shall be based on the free unobstructed area through the windows. Obstructions that can be removed from the windows by the occupant without tools or special knowledge, such as blinds, shades, or operable shutters shall not be included when calculating the unobstructed area. For the purposes of this checklist Item, 90% of the nominal window area of jalousie windows shall be permitted to be used as the free unobstructed area.
24. The pressure boundary is the primary enclosure boundary separating indoor and outdoor air. For example, a volume that has more leakage to outside than to conditioned space would be outside the pressure boundary.
25. Per the 2009 International Mechanical Code, a direct-vent appliance is one that is constructed and installed so that all air for combustion is derived from the outdoor atmosphere and all flue gases are discharged to the outside atmosphere; a mechanical draft system is a venting system designed to remove flue or vent gases by mechanical means consisting of an induced draft portion under non-positive static pressure or a forced draft portion under positive static pressure; and a natural draft system is a venting system designed to remove flue or vent gases under nonpositive static vent pressure entirely by natural draft.
26. Naturally drafted equipment is allowed within the home's pressure boundary in Climate Zones 1-3 if the Rater has followed ANSI/ACCA 12 QH-2014, Section 3.2.2, Appendix A Sections A2.2.6, A3 (Carbon Monoxide Test), and A4 (Depressurization Test for the Combustion Appliance Zone), and verified that the equipment meets the limits defined within.
27. Naturally drafted fireplaces are allowed within the home's pressure boundary if the Rater has verified that the total net rated exhaust flow of the two largest exhaust fans (excluding summer cooling fans) is  $\leq 15$  CFM per 100 sq. ft. of occupiable space when at full capacity. If the net exhaust flow exceeds the allowable limit, it shall be reduced or compensating outdoor airflow provided. Per ASHRAE 62.2-2010, the term "net rated exhaust flow" is defined as flow through an exhaust fan minus the compensating outdoor airflow through any supply fan that is interlocked to the exhaust fan. Per ASHRAE 62.2-2010, the term "occupiable space" is defined as any enclosed space inside the pressure boundary and intended for human activities, including, but not limited to, all habitable spaces, toilets, closets, halls, storage and utility areas, and laundry areas. See Footnote 12 for the definition of "habitable spaces".
28. Alternatively, unvented combustion appliances other than cooking ranges or ovens are permitted to be located inside the home's pressure boundary if the Rater has followed ANSI/ACCA 12 QH-2014, Section 3.2.2, Appendix A Sections A2.2.6, A3, and A4, and verified the equipment meets the limits defined within.
29. The minimum volume of combustion air required for safe operation by the manufacturer and / or code shall be met or exceeded. Also, in accordance with the National Fuel Gas Code, ANSI Z223.1 / NFPA54, unvented room heaters shall not be installed in bathrooms or bedrooms.
30. A continuous stucco cladding system sealed to windows and doors is permitted to be used in lieu of sealing rough openings with caulk or foam.
31. Solar fraction shall be determined using the [ICC-SRCC OG-300 Solar Water Heating System Certification Program's](#) annual solar fraction rating ( $SF_A$ ) for the rating location closest to the home. For Dwelling Units or Sleeping Units with  $\leq 3$  bedrooms, determine  $SF_A$  using the Low U.S. DOE Draw Pattern; otherwise, use Medium. A solar water heater system that has no backup water heater is permitted to be used. For the OG-300 directory, visit <https://solar-rating.org/directories/certified-companies/>.
32. A single mini-split head is permitted to serve one or more bedrooms using up to 10 ft. of ductwork per head.
33. Any Item that will be concealed by drywall (e.g., wall insulation) must be verified during the pre-drywall inspection. If drywall is installed prior to the inspection, then it must be entirely removed to fully verify all Items. It is not sufficient to remove only portions of drywall to inspect a subset of areas. Furthermore, it is not acceptable to complete a Sampled Rating on a home that has missed the pre-drywall inspection. Additional information is available in the [Technical Bulletin: Pre-Drywall Inspection Is Always Required](#).
34. Some Items can typically only be verified at a later stage of construction than when the pre-drywall inspection occurs (e.g., bath fan airflow). Any Item that has not been verified during the pre-drywall inspection must be verified prior to or during the final inspection.