

ENERGY STAR[®]

Residential New Construction Programs

Historical Document

This document is provided for reference because it has been superseded by a more recent Version or Revision. Please find current program documents on the [Program Requirements](#) webpage.

Use of older Versions and Revisions, such as this document, are typically limited to homes and buildings with a permit date (or, for manufactured homes, a production date) prior to a specified date. Consult the [Implementation Timeline](#) table to assess whether a home or apartment is still eligible to be certified using this document.

For questions or more information, contact us at energystarhome@energystar.gov.



ENERGY STAR Single-Family New Homes Florida ERI Target Procedure, Version 3.1 (Rev. 13)

This document provides detailed instructions for determining the ENERGY STAR ERI Target, the highest ERI value that a home may achieve to earn the ENERGY STAR. Note that, in addition to meeting the ENERGY STAR ERI Target, homes shall also meet all Mandatory Requirements for All Certified Homes in Exhibit 2 of the Florida Program Requirements for ENERGY STAR Single-Family New Homes, Version 3.1.

An EPA-recognized Home Certification Organization's Approved Software Rating Tool shall automatically determine (i.e., without relying on a user-configured ENERGY STAR Reference Design) this target for each rated home. This shall be done by configuring the ENERGY STAR Reference Design Home in accordance with Exhibit 1, the Expanded ENERGY STAR Reference Design Definition for the State of Florida, and calculating its associated ERI value. The ERI value shall be calculated using ANSI / RESNET / ICC 301 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the Home Certification Organization (HCO) that the home is being certified under, with approved exceptions listed at www.energystar.gov/ERIEExceptions. This value, rounded to the nearest whole number, shall equal the ENERGY STAR ERI Target.



ENERGY STAR Single-Family New Homes Florida ERI Target Procedure, Version 3.1 (Rev. 13)

Exhibit 1: Expanded ENERGY STAR Reference Design Definition for the State of Florida

| Building Component | Expanded ENERGY STAR Reference Design Definition ¹ | | | | | | | | | | | | | | | | | | |
|---|--|---|-------------------|----------------------|----------------------|-------------------|---------------|-------------------|-----------------------------------|-----------------|------|------|------------------------------------|--------------|-----|------|---|-------|--|
| Foundations: | Construction Type & Structural Mass: Same as Rated Home, except: | | | | | | | | | | | | | | | | | | |
| | • For masonry floor slabs, modeled with 80% of floor area covered by carpet and 20% of floor directly exposed to room air | | | | | | | | | | | | | | | | | | |
| | Conditioning Type: Same as Rated Home, except: | | | | | | | | | | | | | | | | | | |
| | • Crawlspace shall be modeled as vented with net free vent aperture = 1sq. ft. per 150 sq. ft. of crawlspace floor area | | | | | | | | | | | | | | | | | | |
| | Gross Area: Same as Rated Home ² | | | | | | | | | | | | | | | | | | |
| Floors Over Unconditioned Spaces: | Insulation: ^{3,4} Choose appropriate insulation level below: | | | | | | | | | | | | | | | | | | |
| | • Basement Wall Assembly U-factor only applies to conditioned bsmt.'s; if applicable, insulation shall be located on interior side of walls | | | | | | | | | | | | | | | | | | |
| | • Floor assemblies above crawlspace foundations shall be configured to meet the applicable floor assembly U-factor listed in the building component section for Floors Over Unconditioned Spaces | | | | | | | | | | | | | | | | | | |
| | • Slab floors with a floor surface less than 12" below grade shall be insulated to the Slab Insulation R-value. The insulation shall extend downward from the top of the slab on the outside of the foundation wall and then vertically below-grade to the Slab Insulation Depth | | | | | | | | | | | | | | | | | | |
| | <table border="0"> <tr> <td>Climate Zone:</td> <td colspan="3">Florida</td> </tr> <tr> <td>Slab Insulation R-Value:</td> <td colspan="3">0</td> </tr> <tr> <td>Slab Insulation Depth (ft):</td> <td colspan="3">0</td> </tr> <tr> <td>Basement Wall Assembly U-Factor:</td> <td colspan="3">0.360</td> </tr> </table> | | | | Climate Zone: | Florida | | | Slab Insulation R-Value: | 0 | | | Slab Insulation Depth (ft): | 0 | | | Basement Wall Assembly U-Factor: | 0.360 | |
| Climate Zone: | Florida | | | | | | | | | | | | | | | | | | |
| Slab Insulation R-Value: | 0 | | | | | | | | | | | | | | | | | | |
| Slab Insulation Depth (ft): | 0 | | | | | | | | | | | | | | | | | | |
| Basement Wall Assembly U-Factor: | 0.360 | | | | | | | | | | | | | | | | | | |
| Above-Grade Walls: | Interior and Exterior Construction Type: Wood frame | | | | | | | | | | | | | | | | | | |
| | Gross Area: Same as Rated Home | | | | | | | | | | | | | | | | | | |
| | Insulation: ^{3,4} <table border="0"> <tr> <td>Climate Zone:</td> <td colspan="3">Florida</td> </tr> <tr> <td>Floor Assembly U-Factor:</td> <td colspan="3">0.064</td> </tr> </table> | | | | Climate Zone: | Florida | | | Floor Assembly U-Factor: | 0.064 | | | | | | | | | |
| Climate Zone: | Florida | | | | | | | | | | | | | | | | | | |
| Floor Assembly U-Factor: | 0.064 | | | | | | | | | | | | | | | | | | |
| Thermally Isolated Sunrooms: | None | | | | | | | | | | | | | | | | | | |
| | Doors: ⁵ | Area: Same as Rated Home | | | | | | | | | | | | | | | | | |
| | | Orientation: Same as Rated Home | | | | | | | | | | | | | | | | | |
| | | <table border="0"> <tr> <td>Door Type:</td> <td>Opaque</td> <td>≤ 1/2-Lite</td> <td>> 1/2-Lite</td> </tr> <tr> <td>U-Value:</td> <td>0.21</td> <td>0.27</td> <td>0.32</td> </tr> <tr> <td>SHGC:</td> <td>N/A</td> <td>0.30</td> <td>0.30</td> </tr> </table> | | | | Door Type: | Opaque | ≤ 1/2-Lite | > 1/2-Lite | U-Value: | 0.21 | 0.27 | 0.32 | SHGC: | N/A | 0.30 | 0.30 | | |
| Door Type: | | Opaque | ≤ 1/2-Lite | > 1/2-Lite | | | | | | | | | | | | | | | |
| U-Value: | 0.21 | 0.27 | 0.32 | | | | | | | | | | | | | | | | |
| SHGC: | N/A | 0.30 | 0.30 | | | | | | | | | | | | | | | | |
| <table border="0"> <tr> <td>SHGC:</td> <td>N/A</td> <td>0.30</td> <td>0.30</td> </tr> </table> | | | | SHGC: | N/A | 0.30 | 0.30 | | | | | | | | | | | | |
| SHGC: | N/A | 0.30 | 0.30 | | | | | | | | | | | | | | | | |
| Glazing: ⁵ | Total Area: (except in homes with conditioned basements and attached homes) ⁶ | | | | | | | | | | | | | | | | | | |
| | • Same as Rated Home, where Rated Home glazing area is less than 15% of conditioned floor area; <u>OR</u> | | | | | | | | | | | | | | | | | | |
| | • 15% of the conditioned floor area, where the Rated Home glazing area is 15% or more of the conditioned floor area | | | | | | | | | | | | | | | | | | |
| | Orientation: Equally distributed to North, East, South, and West | | | | | | | | | | | | | | | | | | |
| | Interior Shade Coefficient: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301 | | | | | | | | | | | | | | | | | | |
| Skylights: | External Shading: None | | | | | | | | | | | | | | | | | | |
| | <table border="0"> <tr> <td>Climate Zone:</td> <td colspan="3">Florida</td> </tr> <tr> <td>U-Value:</td> <td colspan="3">0.65</td> </tr> <tr> <td>SHGC:</td> <td colspan="3">0.27</td> </tr> </table> | | | | Climate Zone: | Florida | | | U-Value: | 0.65 | | | SHGC: | 0.27 | | | | | |
| | Climate Zone: | Florida | | | | | | | | | | | | | | | | | |
| | U-Value: | 0.65 | | | | | | | | | | | | | | | | | |
| | SHGC: | 0.27 | | | | | | | | | | | | | | | | | |
| None | | | | | | | | | | | | | | | | | | | |
| Ceilings: | Construction Type: Wood frame | | | | | | | | | | | | | | | | | | |
| | Gross Area: Same as Rated Home | | | | | | | | | | | | | | | | | | |
| | Insulation: ³ <table border="0"> <tr> <td>Climate Zone:</td> <td colspan="3">Florida</td> </tr> <tr> <td>Ceiling Assembly U-Factor:</td> <td colspan="3">0.035</td> </tr> </table> | | | | Climate Zone: | Florida | | | Ceiling Assembly U-Factor: | 0.035 | | | | | | | | | |
| Climate Zone: | Florida | | | | | | | | | | | | | | | | | | |
| Ceiling Assembly U-Factor: | 0.035 | | | | | | | | | | | | | | | | | | |
| Attics: | Construction Type: Vented with aperture = 1sq. ft. per 300 sq. ft. ceiling area | | | | | | | | | | | | | | | | | | |
| | Radiant Barrier: Included, with a minimum initial reflectance of 0.90 and maximum initial emittance of 0.10 | | | | | | | | | | | | | | | | | | |
| Roofs: | Construction Type: Composition shingle on wood sheathing | | | | | | | | | | | | | | | | | | |
| | Gross Area: Same as Rated Home | | | | | | | | | | | | | | | | | | |
| | Solar Absorptance = 0.92 | | | | | | | | | | | | | | | | | | |
| Internal Mass: | Emittance = 0.90 | | | | | | | | | | | | | | | | | | |
| | Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301. | | | | | | | | | | | | | | | | | | |
| Lighting, Appliances, & Internal Gains: | Additional mass specifically designed as a Thermal Storage Element for the Rated Home shall be excluded. | | | | | | | | | | | | | | | | | | |
| | Lighting: Fraction of qualifying Tier I fixtures to all fixtures in qualifying light fixture locations: 80% for interior, 0% for exterior and garage | | | | | | | | | | | | | | | | | | |
| | Refrigerator: 423 kWh per year | | | | | | | | | | | | | | | | | | |
| | Dishwasher: Capacity Same as Rated Home, or Standard if no dishwasher in the Rated Home | | | | | | | | | | | | | | | | | | |
| | For Standard capacity: LER = 270, GHWC = \$22.23, Elec\$ = \$0.12, Gas\$ = \$1.09, LCY = 208 | | | | | | | | | | | | | | | | | | |
| | For Compact capacity: LER = 203, GHWC = \$14.20, Elec\$ = \$0.12, Gas\$ = \$1.09, LCY = 208 | | | | | | | | | | | | | | | | | | |
| | Ceiling Fan: 122 CFM per Watt; Quantity = Same as Rated Home per ANSI / RESNET / ICC 301, either 0 or Number of bedrooms+1 | | | | | | | | | | | | | | | | | | |
| Internal Gains: | Clothes Washer and Dryer: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301 | | | | | | | | | | | | | | | | | | |
| | Internal Gains: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301, except for adjustments for the lighting, refrigerator, dishwasher, and ceiling fans specified in this Section. | | | | | | | | | | | | | | | | | | |



ENERGY STAR Single-Family New Homes Florida ERI Target Procedure, Version 3.1 (Rev. 13)

Footnotes:

1. Any parameter not specified in this exhibit shall be identical to the value entered for the Rated Home.
2. "Same as Rated Home" indicates that the parameter shall be identical to the value entered for the Rated Home.
3. Slab insulation R-values represent nominal insulation levels; and assembly U-factors for foundations, floors, walls, and ceilings represent the overall assembly, inclusive of sheathing materials, cavity insulation, installation quality, framing, and interior finishes.
4. If software allows the user to specify the thermal boundary location independent of the conditioned space boundary in the basement of the rated home, then the thermal boundary of the ENERGY STAR Reference Design shall be aligned with this boundary. For example, if the thermal boundary is located at the walls, then the wall insulation shall be configured as if it was a conditioned basement. If the thermal boundary is located at the floor above the basement, then the floor insulation shall be configured as if it was a floor over an unconditioned space.
5. Note that the U-factor requirement applies to all fenestration while the SHGC only applies to the glazed portion.
6. When determining the ENERGY STAR ERI Target for homes with conditioned basements and for attached homes, the following formula shall be used to determine total window area of the ENERGY STAR Reference Design:

$$AG = 0.15 \times CFA \times FA \times F$$

Where:

- AG = Total glazing area
- CFA = Total conditioned floor area
- FA = (Gross above-grade thermal boundary wall area) / (Gross above-grade thermal boundary wall area + 0.5 x Gross below-grade thermal boundary wall area)
- F = 1 - 0.44 x (Gross common wall area) / (Gross above-grade thermal boundary wall area + Gross common wall area)

And where:

- Thermal boundary wall is any wall that separates Conditioned Space from Unconditioned Space, outdoor environment, or the surrounding soil;
 - Above-grade thermal boundary wall is any portion of a thermal boundary wall not in contact with soil;
 - Below-grade thermal boundary wall is any portion of a thermal boundary wall in soil contact; and
 - Common wall is the total wall area of walls adjacent to another conditioned living unit, not including foundation walls.
7. Fuel type(s) shall be same as Rated Home, including any dual-fuel equipment where applicable. For a Rated Home with multiple heating, cooling, or water heating systems using different fuel types, the applicable system capacities and fuel types shall be weighted in accordance with the loads distribution (as calculated by accepted engineering practice for that equipment and fuel type) of the multiple systems.
 8. For a Rated Home without a heating system, the ENERGY STAR Reference Design Home shall be configured with a 78% AFUE gas furnace system, unless the Rated home has no access to natural gas or fossil fuel delivery. In such cases, the ENERGY STAR Reference Design Home shall be configured with a 7.7 HSPF air-source heat pump.
 9. For a Rated Home without a cooling system, the ENERGY STAR Reference Design Home shall be configured with a 13 SEER electric air conditioner.
 10. That is to say, representative of standard-flow plumbing fixtures, reference clothes washer gallons per day, standard distribution system water use effectiveness, a hot water piping ratio of 1.0, no pipe insulation, and no drainwater heat recovery.
 11. To determine domestic hot water (DHW) EF requirements for additional tank sizes, use the following equations: Gas DHW EF $\geq 0.69 - (0.002 \times \text{Tank Gallon Capacity})$; Electric DHW EF $\geq 0.97 - (0.001 \times \text{Tank Gallon Capacity})$; Oil DHW EF $\geq 0.61 - (0.002 \times \text{Tank Gallon Capacity})$.