

ENERGY STAR[®]

Residential New Construction Programs

Historical Document

This document is provided for reference because it has been superseded by a more recent Version or Revision. Please find current program documents on the [Program Requirements](#) webpage.

Use of older Versions and Revisions, such as this document, are typically limited to homes and buildings with a permit date (or, for manufactured homes, a production date) prior to a specified date. Consult the [Implementation Timeline](#) table to assess whether a home or apartment is still eligible to be certified using this document.

For questions or more information, contact us at energystarhome@energystar.gov.



ENERGY STAR Single-Family New Homes

Oregon and Washington ERI Target Procedure, Version 3.2 (Rev. 13)

This document provides instructions for determining the ENERGY STAR ERI Target, the highest ERI value that each rated home may achieve to earn the ENERGY STAR. Note that, in addition to meeting the ENERGY STAR ERI Target, homes shall also meet all Mandatory Requirements for All Certified Homes in Exhibit 2 of the Oregon and Washington Program Requirements for ENERGY STAR Single-Family New Homes, Version 3.2.

An EPA-recognized Home Certification Organization's Approved Software Rating Tool shall automatically determine (i.e., without relying on a user-configured ENERGY STAR Reference Design) this target for each rated home. This shall be done by configuring the ENERGY STAR Reference Design Home in accordance with Exhibit 1, the Expanded ENERGY STAR Reference Design Definition, and calculating its associated ERI value. The ERI value shall be calculated using ANSI / RESNET / ICC 301 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the Home Certification Organization (HCO) that the home is being certified under, with approved exceptions listed at www.energystar.gov/ERIEExceptions. This value, rounded to the nearest whole number, shall equal the ENERGY STAR ERI Target.



ENERGY STAR Single-Family New Homes

Oregon and Washington ERI Target Procedure, Version 3.2 (Rev. 13)

Exhibit 1: Expanded ENERGY STAR Reference Design Definition for the States of Oregon and Washington

Building Component	Expanded ENERGY STAR Reference Design Definition ¹			
Foundations:	Construction Type & Structural Mass: Same as Rated Home, except: <ul style="list-style-type: none"> For masonry floor slabs, modeled with 80% of floor area covered by carpet and 20% of floor directly exposed to room air 			
	Conditioning Type: Same as Rated Home, except: <ul style="list-style-type: none"> Crawlspaces shall be modeled as vented with net free vent aperture = 1sq. ft. per 150 sq. ft. of crawlspace floor area 			
	Gross Area: Same as Rated Home ²			
	Insulation: ^{3,4} Choose appropriate insulation level below: <ul style="list-style-type: none"> Basement Wall Assembly U-factor only applies to conditioned bsmt.'s; if applicable, insulation shall be located on interior side of walls Floor assemblies above crawlspace foundations shall be configured to meet the applicable floor assembly U-factor listed in the building component section for Floors Over Unconditioned Spaces On-grade and below-grade slab floors shall be insulated to the Slab Insulation R-value at both the perimeter for the entire depth of the slab, or 2 ft. if slab depth is not specified by user, and under the entire slab area 			
	Climate Zone: ⁵	CZ 4C & 5	CZ 6	
	Slab Insulation R-Value:	10	10	
	Basement Wall Assembly U-Factor:	0.042	0.042	
Floors Over Unconditioned Spaces:	Construction Type: Wood frame			
	Gross Area: Same as Rated Home			
	Insulation: ^{3,4} Climate Zone: ⁵			
	Floor Assembly U-Factor:	CZ 4C & 5	CZ 6	
		0.028	0.028	
Above-Grade Walls:	Interior and Exterior Construction Type: Wood frame			
	Gross Area: Same as Rated Home			
	Solar Absorptance = 0.75			
	Emittance = 0.90			
	Insulation: ³ Climate Zone: ⁵	CZ 4C & 5	CZ 6	
	Wall Assembly U-Factor:	0.056	0.056	
Thermally Isolated Sunrooms:	None			
Doors: ⁶	Area: Same as Rated Home			
	Orientation: Same as Rated Home			
	Door Type:	Opaque	≤ 1/2-Lite	> 1/2-Lite
	U-Value:	0.17	0.25	0.30
	SHGC:	N/A	0.25	0.30
Glazing: ⁶	Total Area: (except in homes with conditioned basements and attached homes ⁷) <ul style="list-style-type: none"> Same as Rated Home, where Rated Home glazing area is less than 15% of conditioned floor area; OR 15% of the conditioned floor area, where the Rated Home glazing area is 15% or more of the conditioned floor area 			
	Orientation: Equally distributed to North, East, South, and West			
	Interior Shade Coefficient: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301			
	External Shading: None			
		Climate Zone: ⁵	CZ 4C & 5	CZ 6
		U-Value:	0.27	0.27
	SHGC:	0.30	0.30	
Skylights:	None			
Ceilings:	Construction Type: Wood frame			
	Gross Area: Same as Rated Home			
	Insulation: ³ Climate Zone: ⁵			
	Ceiling Assembly U-Factor:	CZ 4C & 5	CZ 6	
		0.026	0.026	
Attics:	Construction Type: Vented with aperture = 1sq. ft. per 300 sq. ft. ceiling area			
	Radiant Barrier: None			
Roofs:	Construction Type: Composition shingle on wood sheathing			
	Gross Area: Same as Rated Home			
	Solar Absorptance = 0.92			
	Emittance = 0.90			
Internal Mass:	Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301			
	Additional mass specifically designed as a Thermal Storage Element for the Rated Home shall be excluded.			
Lighting, Appliances, & Internal Gains:	Lighting: Fraction of qualifying Tier I fixtures to all fixtures in qualifying light fixture locations: 90% for interior; 0% for exterior and garage			
	Refrigerator: 423 kWh per year			
	Dishwasher: Capacity Same as Rated Home, or Standard if no dishwasher in the Rated Home			
	For Standard capacity: LER = 270, GHWC = \$22.23, Elec\$ = \$0.12, Gas\$ = \$1.09, LCY = 208			
	For Compact capacity: LER = 203, GHWC = \$14.20, Elec\$ = \$0.12, Gas\$ = \$1.09, LCY = 208			
	Ceiling Fan: 122 CFM per Watt; Quantity = Same as Rated Home per ANSI / RESNET / ICC 301, either 0 or Number of bedrooms + 1			
Clothes Washer and Dryer: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301				
Internal Gains: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301, except for adjustments for the lighting, refrigerator, dishwasher, and ceiling fans specified in this Section.				



ENERGY STAR Single-Family New Homes

Oregon and Washington ERI Target Procedure, Version 3.2 (Rev. 13)

Exhibit 1: Expanded ENERGY STAR Reference Design Definition for the States of Oregon and Washington (Continued)

Heating Systems:	Heating capacity shall be selected in accordance with ACCA Manual S based on building heating and cooling loads calculated in accordance with ACCA Manual J, Eighth Edition, ASHRAE Handbook of Fundamentals, or an equivalent computation procedure. For forced-air HVAC systems, degraded capacity from Grade III install shall be accounted for using same methodology applied to Energy Rating Reference Home.		
	Fuel Type: Same as Rated Home ⁸		
	Installation Quality: For forced-air HVAC systems, Grade III airflow and watt draw; for air-source heat pumps, also Grade III ref. charge.		
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump where Rated Home has air-source or ground-source heat pump, electric strip heat, or electric baseboard heat; applicable efficiency selected from below. ⁹		
	Climate Zone: ⁵	CZ 4C & 5	CZ 6
	Gas Furn. AFUE:	95	95
	Oil Furn. AFUE:	85	85
	Gas Boiler AFUE:	90	90
	Oil Boiler AFUE:	86	86
	Air-Source Heat Pump HSPF:	9.5	9.5
Air-Source Heat Pump Backup:	Electric	Electric	
For non-electric boilers, the Electric Auxiliary Energy shall be determined in accordance with the methodology for the Energy Rating Reference Home in ANSI / RESNET / ICC 301.			
Cooling Systems:	Cooling capacity shall be selected in accordance with ACCA Manual S based on building heating and cooling loads calculated in accordance with ACCA Manual J, Eighth Edition, ASHRAE Handbook of Fundamentals, or an equivalent computation procedure. For forced-air HVAC systems, degraded capacity from Grade III install shall be accounted for using same methodology applied to Energy Rating Reference Home.		
	Fuel Type: Same as Rated Home ⁸		
	Installation Quality: For forced-air HVAC systems, Grade III airflow and watt draw; for AC's & air-source heat pumps, also Grade III ref. charge.		
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump where Rated Home has air-source or ground-source heat pump, electric strip heat, or electric baseboard heat; applicable efficiency selected from below. ¹⁰		
	Climate Zone: ⁵	CZ 4C & 5	CZ 6
	AC SEER:	13	13
Air-Source Heat Pump SEER:	15	15	
Service Water Heating Systems:	Use (Gallons per Day): Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301, except for reduced usage resulting from low-flow plumbing fixtures, R-3 pipe insulation, and the dishwasher specified in the Lighting, Appliances, & Internal Gains Section. ¹¹		
	Tank Temperature: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301		
	Fuel Type & System Type: If Rated Home uses a system with a gas or propane fuel type, model as instantaneous gas water heater with no solar heating. If Rated Home uses a system with an oil, electric, or other fuel type, model as 60 gallon electric heat pump water heater with no solar heating. Select applicable efficiency from below. ¹²		
	Climate Zone: ⁵	CZ 4C & 5	CZ 6
	Gas DHW EF:	0.91	0.91
Electric DHW EF:	2.5	2.0	
Thermal Distribution Systems:	Duct Leakage to Outside: The greater of 4 CFM25 per 100 sq. ft. of conditioned floor area or 40 CFM25		
	Duct Insulation: R-8 on all ducts located in unconditioned space		
	Duct Surface Area: Same as Rated Home		
	Supply and Return Duct Locations shall be configured according to the table below or, if Rated home does not meet any of the conditions below (e.g., multifamily dwelling unit with conditioned unit below), then duct locations shall be configured to be 100% in attic space.		
	Foundation Type:	Slab	Crawlspace
One Story Above Grade:	100% Attic	100% Crawlspace	100% Basement
Two Story Above Grade:	75% Attic / 25% Conditioned	50% Attic / 50% Crawlspace	50% Attic / 50% Basement
Thermostat:	Type: Programmable		
	Temperature Setpoints: Same as Energy Rating Reference home, but with offsets for a programmable thermostat, as defined by ANSI / RESNET / ICC 301		
Dehumidifiers	Type, capacity, efficacy, and dehumidistat setpoint same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC 301, when dehumidification system is present in Rated home; otherwise none.		
Infiltration & Mechanical Ventilation:	Infiltration Rates: Climate Zone: ⁵	CZ 4C & 5	CZ 6
	ACH50:	3	3
	Mechanical ventilation system without heat recovery		
	Rate: CFM = 0.01 * CFA + 7.5 * (Nbr + 1), where CFA = Conditioned Floor Area and Nbr = Number of Bedrooms		
	Runtime: 24 Hours per Day		
	Fan Watts: Watts = CFM Rate / 2.8 CFM per Watt, where CFM Rate is determined above		
Climate Zone: ⁵	CZ 4C & 5	CZ 6	
Ventilation Type:	Exhaust	Exhaust	
On-Site Power Production	None		



ENERGY STAR Single-Family New Homes

Oregon and Washington ERI Target Procedure, Version 3.2 (Rev. 13)

Footnotes:

1. Any parameter not specified in this exhibit shall be identical to the value entered for the Rated Home.
2. "Same as Rated Home" indicates that the parameter shall be identical to the value entered for the Rated Home.
3. Slab insulation R-values represent nominal insulation levels; and assembly U-factors for foundations, floors, walls, and ceilings represent the overall assembly, inclusive of sheathing materials, cavity insulation, installation quality, framing, and interior finishes.
4. If software allows the user to specify the thermal boundary location independent of the conditioned space boundary in the basement of the rated home, then the thermal boundary of the ENERGY STAR Reference Design shall be aligned with this boundary. For example, if the thermal boundary is located at the walls, then the wall insulation shall be configured as if it was a conditioned basement. If the thermal boundary is located at the floor above the basement, then the floor insulation shall be configured as if it was a floor over an unconditioned space.
5. 2012 IECC Climate Zone designations, as defined and illustrated in Section R301 of the code, shall be used to configure the ENERGY STAR Reference Design Home in Oregon and Washington Version 3.2.
6. Note that the U-factor requirement applies to all fenestration while the SHGC only applies to the glazed portion.
7. When determining the ENERGY STAR ERI Target for homes with conditioned basements and for attached homes, the following formula shall be used to determine total window area of the ENERGY STAR Reference Design:

$$AG = 0.15 \times CFA \times FA \times F$$

Where:

- AG = Total glazing area
- CFA = Total conditioned floor area
- FA = (Gross above-grade thermal boundary wall area) / (Gross above-grade thermal boundary wall area + 0.5 x Gross below-grade thermal boundary wall area)
- F = $1 - 0.44 \times (\text{Gross common wall area}) / (\text{Gross above-grade thermal boundary wall area} + \text{Gross common wall area})$

And where:

- Thermal boundary wall is any wall that separates Conditioned Space from Unconditioned Space, outdoor environment, or the surrounding soil;
 - Above-grade thermal boundary wall is any portion of a thermal boundary wall not in contact with soil;
 - Below-grade thermal boundary wall is any portion of a thermal boundary wall in soil contact; and
 - Common wall is the total wall area of walls adjacent to another conditioned living unit, not including foundation walls.
8. Fuel type(s) shall be same as Rated Home, including any dual-fuel equipment where applicable. For a Rated Home with multiple heating or cooling systems using different fuel types, the applicable system capacities and fuel types shall be weighted in accordance with the loads distribution (as calculated by accepted engineering practice for that equipment and fuel type) of the multiple systems.
 9. For a Rated Home without a heating system, the ENERGY STAR Reference Design Home shall be configured with a 78% AFUE gas furnace system, unless the Rated home has no access to natural gas or fossil fuel delivery. In such cases, the ENERGY STAR Reference Design Home shall be configured with a 7.7 HSPF air-source heat pump.
 10. For a Rated Home without a cooling system, the ENERGY STAR Reference Design Home shall be configured with a 13 SEER electric air conditioner.
 11. That is to say, representative of reference clothes washer gallons per day, standard distribution system water use effectiveness, a hot water piping ratio of 1.0, and no drainwater heat recovery.
 12. For a Rated Home with multiple water heating systems using different fuel types, the system capacities and fuel types shall be weighted in accordance with the loads distribution (as calculated by accepted engineering practice for that equipment and fuel type) of the multiple systems.