



January 30, 2015

VIA EMAIL To: lamps@energystar.gov

Ms. Taylor Jantz-Sell
Environmental Protection Agency
ENERGY STAR Lighting Program Manager
1200 Penn. Ave NW 6202J
Washington, DC 20460

TCP Comments on Draft 1 ENERGY STAR® Program Luminaires V2.0.

Dear Ms. Jantz-Sell,

Technical Consumer Products, Inc. appreciates the opportunity to provide our comments to the latest proposed luminaires specification.

- 1) TCP has concerns with the R9 equal or greater than 0. We believe that significant redesign is required in order for 2700K lamps to meet this requirement. This comes at a cost of LPW (decreased). R9 has never been a requirement for CFL's, thus they have not been designed with this in mind. Deep red phosphors to meet R9 greater than 0 results in lower LPW and higher cost.
Recommend: removing R9 for CFL's.

Thank you and if you have any additional questions please feel free to contact me.

Sincerely,
Tammie Madden
ENERGY STAR Program Manager