

June 11, 2019

To: energystarhomes@energystar.gov

**From: Systems Building Research Alliance**

RE: ENERGY STAR Manufactured Homes Program, Version 2

Comments:

1. **Page 1, ENERGY STAR Certification Process, Item 6:** Add clarification that field evaluations shall be conducted on multi-section homes.

“The QAP will coordinate with the plant on an ongoing basis to conduct periodic field evaluations of ENERGY STAR certified manufactured homes. Field evaluations shall be conducted on no less than two percent (2%) of a plant’s ENERGY STAR certified multi-section manufactured homes sold and installed on a homeowner’s site, or a minimum of one home each calendar year, whichever is greater.”

2. **Page 2, Exhibit 1, High-Efficiency Furnace Package:** The word “of” is missing in the SHGC bullet item.

“The solar heat gain coefficient of glazing shall not exceed...”