



# ENERGY STAR Single-Family New Homes California Program Requirements, Version 3.2 (Rev. 12)

## Eligibility Requirements

Site-built or modular <sup>1</sup> Dwellings <sup>2</sup> (e.g., single-family homes and duplexes) and Townhouses <sup>3</sup> are eligible to participate in the ENERGY STAR Single-Family New Homes (SFNH) program.

Dwelling Units in certain low-rise multifamily buildings are also eligible to participate in the ENERGY STAR SFNH program if permitted prior to July 1, 2021. See Footnote 4 for details. <sup>4</sup>

While primarily intended for new construction, existing homes (e.g., undergoing a gut rehabilitation) are also eligible to participate in the ENERGY STAR SFNH program, with guidance available at: [www.energystar.gov/GutRehabGuidance](http://www.energystar.gov/GutRehabGuidance).

For information about other ENERGY STAR residential new construction programs, visit [www.energystar.gov/newhomesrequirements](http://www.energystar.gov/newhomesrequirements).

Note that compliance with these requirements is not intended to imply compliance with all local code requirements. <sup>5</sup>

## Partnership, Training, and Credentialing Requirements

The following requirements must be met prior to certifying homes:

- Builders are required to sign an ENERGY STAR Partnership Agreement and complete the online Version 3 Builder Orientation, which can be found at [www.energystar.gov/homesPA](http://www.energystar.gov/homesPA).
- HVAC installing contractors are required to be credentialed by an EPA-recognized HVAC Quality Installation Training and Oversight Organization (H-QUITO) for homes certified using Track B in Exhibit 1. An explanation of this process can be found at [www.energystar.gov/newhomesHVAC](http://www.energystar.gov/newhomesHVAC).
- Energy Rating Companies (e.g., rater companies and Providers <sup>6</sup>) are required to sign an ENERGY STAR Partnership Agreement, which can be found at [www.energystar.gov/homesPA](http://www.energystar.gov/homesPA), and Raters <sup>7</sup> are required to complete EPA-recognized training, which can be found at [www.energystar.gov/newhomestraining](http://www.energystar.gov/newhomestraining).

## ENERGY STAR Certification Process

1. The certification process provides flexibility to select a custom combination of measures for each home that meets one of two performance targets, as assessed through energy modeling. Select one of the two following performance targets:
  - a. A Delta Energy Design Rating (Delta EDR) of  $\geq 3$  points, as determined by a CEC-approved software program. <sup>8</sup> On-site power generation may not be used to meet the performance target and must be demonstrated using the EDR score that excludes photovoltaics.
  - b. A Compliance Total with  $\geq 10\%$  savings above the Compliance Total of the Standard Design corresponding to the home, as determined by a CEC-approved software program. <sup>8</sup> On-site power generation may not be used to meet the above-code performance target, though it is permitted to be used to satisfy code, in accordance with the 2016 Building Energy Efficiency Standards.

2. Configure the preferred set of efficiency measures for the home to be certified and verify that the resulting performance meets or exceeds the applicable performance target using the applicable software program, as determined in Step 1.

Note that, regardless of the measures selected, the Mandatory Requirements for All Certified Homes in Exhibit 1 are also required and impose certain constraints on the efficiency measures selected (e.g., insulation levels, insulation installation quality, window performance, duct leakage).

3. Construct the home using the measures selected in Step 2 and the Mandatory Requirements for All Certified Homes, Exhibit 1.
4. Using a Rater, verify that all requirements have been met in accordance with the Mandatory Requirements for All Certified Homes and with Data Input requirements and On-Site Inspection Procedures for California HERS Ratings. <sup>7,9</sup> For modular homes, a Rater must verify any requirement in the plant not able to be verified on-site because a feature will be concealed prior to shipment. Finally, register the rated home with a CEC-approved HERS Provider. The Rater is required to keep electronic or hard copies of the completed and signed National Rater checklists and either an HVAC design report compliant with ANSI / RESNET / ACCA / ICC 310, and the National HVAC Design Supplement to Std. 310 for Dwellings & Units, for homes using Track A, or the National HVAC Design Report for homes using Track B.

The Rater must review all items on the National Rater checklists. Raters are expected to use their experience and discretion to verify that the overall intent of each inspection checklist item has been met (i.e., identifying major defects that undermine the intent of the checklist item versus identifying minor defects that the Rater may deem acceptable).

In the event that a Rater finds an item that is inconsistent with the intent of the checklists, the home cannot earn the ENERGY STAR until the item is corrected. If correction of the item is not possible, the home cannot earn the ENERGY STAR. In the event that an item on a National Rater checklist cannot be inspected by the Rater, the home cannot earn the ENERGY STAR. The only exceptions to this rule are in the Thermal Enclosure System Section of the National Rater Field Checklist, where the builder may assume responsibility for verifying a maximum of eight items. This option shall only be used at the discretion of the Rater. When exercised, the builder's responsibility will be formally acknowledged by the builder signing the checklist for the item(s) they verified.

In the event that a Rater is not able to determine whether an item is consistent with the intent (e.g., an alternative method of meeting a checklist requirement has been proposed), then the Rater shall consult their Provider. If the Provider also cannot make this determination, then the Rater or Provider shall report the issue to EPA prior to project completion at: [energystarhomes@energystar.gov](mailto:energystarhomes@energystar.gov) and will receive an initial response within 5 business days. If EPA believes the current program requirements are sufficiently clear to determine whether the intent has been met, then this guidance will be provided to the partner and enforced beginning with the house in question. In contrast, if EPA believes the program requirements require revisions to make the intent clear, then this guidance will be provided to the partner but only enforced for homes permitted after a specified transition period after the release of the revised program requirements, typically 60 days in length.

This will allow EPA to make formal policy decisions as partner questions arise and to disseminate these policy decisions through the [Policy Record](#) and the periodic release of revised program documents to ensure consistent application of the program requirements.



# ENERGY STAR Single-Family New Homes California Program Requirements, Version 3.2 (Rev. 12)

Two tracks are provided for satisfying the mandatory requirements for all certified homes, Exhibit 1. Track A - HVAC Grading utilizes ANSI / RESNET / ACCA / ICC 310 <sup>10</sup>, a standard for grading the installation of HVAC systems. Track B - HVAC Credential utilizes an HVAC contractor credentialed by an EPA-recognized H-QUITO. Either track may be selected, but all requirements within that track must be satisfied for the home to be certified.

## Exhibit 1: Mandatory Requirements for All Certified Homes

Party Responsible	Mandatory Requirements
<b>Requirements Applicable to Track A &amp; B</b>	
<b>Rater</b>	<ul style="list-style-type: none"> <li>• Completion of SFNH National Rater Design Review Checklist, Version 3 / 3.1 / 3.2</li> <li>• Completion of SFNH National Rater Field Checklist, Version 3 / 3.1 / 3.2</li> </ul>
<b>Builder</b>	<ul style="list-style-type: none"> <li>• Completion of SFNH National Water Mgmt. System Builder Reqs., Version 3 / 3.1 / 3.2</li> </ul>
<b>Requirements Only Applicable to Track A – HVAC Grading <sup>10</sup></b>	
<b>HVAC System Designer</b>	<ul style="list-style-type: none"> <li>• Completion of an HVAC design report compliant with ANSI / RESNET / ACCA / ICC 310, plus the SFNH / MFNC National HVAC Design Supplement to Std. 310 for Dwellings &amp; Units, All Versions.</li> </ul>
<b>HVAC Installing Contractor</b>	<ul style="list-style-type: none"> <li>• None. While the HVAC contractor plays a critical role in properly installing and commissioning a system, the Rater is the party responsible for assessing its installation quality in accordance with ANSI / RESNET / ACCA / ICC 310.</li> </ul>
<b>Requirements Only Applicable to Track B – HVAC Credential</b>	
<b>HVAC System Designer</b>	<ul style="list-style-type: none"> <li>• Completion of SFNH National HVAC Design Report, Version 3 / 3.1 / 3.2</li> </ul>
<b>HVAC Installing Contractor</b>	<ul style="list-style-type: none"> <li>• Completion of SFNH National HVAC Commissioning Checklist, Version 3 / 3.1 / 3.2</li> </ul>

### Effective Date

To determine the program Version and Revision that a home is required to be certified under, look up the plan approval date and permit issue date of the home in Exhibit 2. Program requirements for other locations can be found at [www.energystar.gov/newhomesrequirements](http://www.energystar.gov/newhomesrequirements).

This Exhibit contains all implementation timelines applicable on or after October 1, 2020. Implementation timelines applicable prior to this date can be obtained by contacting [energystarhomes@energystar.gov](mailto:energystarhomes@energystar.gov).

## Exhibit 2: ENERGY STAR Single-Family New Homes Implementation Timeline for California

State / Territory	Homes With Plan Approval Date and Permit Issue Date On or After This Date Must Meet the Adjacent Version & Revision (See Footnote 11 for Definition & Exception <sup>11</sup> )	Version	Revision <sup>12</sup>
CA	10-01-2020	California v3.2	Rev. 10
	01-01-2022	California v3.2	Rev. 11
	01-01-2023	California v3.3	Rev. 11
	01-01-2024	California v3.3	Rev. 12

### Footnotes:

1. A modular home is a prefabricated home that is made of multiple modules or sections that are manufactured and substantially assembled in a manufacturing plant. These pre-built sections are transported to the building site and constructed by a builder to meet all applicable building codes for site-built homes.
2. A Dwelling, as defined by ANSI / RESNET / ICC 301, is any building that contains one or two Dwelling Units used, intended, or designed to be built, used, rented, leased, let or hired out to be occupied, or that are occupied for living purposes. ANSI / RESNET / ICC 301 defines a Dwelling Unit as a single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking, and sanitation.
3. A Townhouse, as defined by ANSI / RESNET / ICC 301, is a single-family Dwelling Unit constructed in a group of three or more attached units in which each unit extends from the foundation to roof and with open space on at least two sides. Townhouses are also eligible to participate in the ENERGY STAR Multifamily New Construction Program.
4. If permitted prior to July 1, 2021, the following are also eligible to participate in the ENERGY STAR SFNH program:
  - Dwelling units <sup>2</sup> in any multifamily building with 4 units or fewer; OR
  - Dwelling units in multifamily buildings with 3 stories or fewer above-grade; OR



# ENERGY STAR Single-Family New Homes California Program Requirements, Version 3.2 (Rev. 12)

- Dwelling units in multifamily buildings with 4 or 5 stories above-grade where dwelling units occupy 80% or more of the occupiable square footage of the building. When evaluating mixed-use buildings for eligibility, exclude commercial / retail space when assessing whether the 80% threshold has been met.

Any above-grade story with 20% or more occupiable space, including commercial space, shall be counted towards the total number of stories for the purpose of determining eligibility to participate in the program. The definition of an 'above-grade story' is one for which more than half of the gross surface area of the exterior walls is above-grade. All below-grade stories, regardless of type, shall not be included when evaluating eligibility.

Per ASHRAE 62.2-2010, occupiable space is any enclosed space inside the pressure boundary and intended for human activities or continual human occupancy, including, but not limited to, areas used for living, sleeping, dining, and cooking, toilets, closets, halls, storage and utility areas, and laundry areas.

5. While certification will result in compliance with many code requirements, a Rater is not responsible for ensuring that all code requirements have been met prior to certification. For more information about how these program requirements help satisfy code requirements, visit: [www.energystar.gov/newhomesguidance](http://www.energystar.gov/newhomesguidance). In the event that a code requirement, a manufacturer's installation instructions, or an engineering document conflict with a requirement of the ENERGY STAR program (e.g., slab insulation is prohibited to allow visual access for termite inspections), then the conflicting requirement within these program requirements shall not be met. Certification shall only be allowed if the Rater has determined that no equivalent option is available that could meet the intent of the conflicting requirement (e.g., switching from exterior to interior slab edge insulation). Note that a home must still meet its ENERGY STAR ERI Target. Therefore, other efficiency measures may be needed to compensate for the omission of the conflicting requirement.
6. The term 'Provider' refers to an Approved Rating Provider as defined by ANSI / RESNET / ICC 301.
7. The term 'Rater' refers to the person(s) completing the third-party verification required for certification. The person(s) shall: a) be a Certified Rater or Approved Inspector, as defined by ANSI / RESNET / ICC 301; and, b) have attended and successfully completed an EPA-recognized training class. See [www.energystar.gov/newhomestraining](http://www.energystar.gov/newhomestraining).
8. Information on the Delta EDR can be found at [https://cahp-pge.com/CAHP\\_TRC\\_Generation%20of%20EDR\\_2017.pdf](https://cahp-pge.com/CAHP_TRC_Generation%20of%20EDR_2017.pdf). CEC-approved computer programs can be found at: [www.energy.ca.gov/title24/2016standards/2016\\_computer\\_prog\\_list.html](http://www.energy.ca.gov/title24/2016standards/2016_computer_prog_list.html).
9. Raters who operate under a Sampling Provider are permitted to verify the Minimum Rated Features of the home and to verify any Checklist Item designated "Rater Verified" using the CEC-approved sampling protocol for homes in CA. No parties other than Raters are permitted to use sampling. All other items shall be verified for each certified home. For example, no items on the National HVAC Commissioning Checklist are permitted to be verified using a sampling protocol.
10. Track A – HVAC Grading shall use ANSI / RESNET / ACCA / ICC 310 including all Addenda and Normative Appendices, with new versions and Addenda implemented according to the schedule defined by the HCO that the home is being certified under.
11. The 'plan approval date' is the date that a jurisdiction approves a home plan and its efficiency features for use on a specific lot or tract. The Rater may define the 'permit date' as either the date that the permit was issued or the date of the contract on the home. In cases where permit or contract dates are not available, Providers have discretion to estimate permit dates based on other construction schedule factors. These assumptions should be both defensible and documented. As an exception, if a new plan is added to a specific tract's existing plan set and the new plan is subject to the same version of the energy code as the existing plan set, then the 'plan approval date' is considered to be the existing plan set's original plan approval date.
12. Homes certified under Rev. 12 of the program requirements are permitted to use either Rev. 08, 09, 10, 11, or 12 of the National HVAC Design Report.