

WINDOWS

CLIMATE ZONE	U-FACTOR ¹	SHGC ²	
Northern	≤ 0.27	Any	Prescriptive
	≤ 0.28	≥ 0.32	Equivalent Energy Performance
	≤ 0.29	≥ 0.37	
	≤ 0.30	≥ 0.42	
North Central	≤ 0.30	≤ 0.40	
South Central	≤ 0.30	≤ 0.25	
Southern	≤ 0.40	≤ 0.25	

SKYLIGHTS

CLIMATE ZONE	U-FACTOR ¹	SHGC ²
Northern	≤ 0.50	Any
North Central	≤ 0.53	≤ 0.35
South Central	≤ 0.53	≤ 0.28
Southern	≤ 0.60	≤ 0.28

Air Leakage ≤ 0.3 cfm/ft²

¹ Btu/h ft²·°F

² Solar Heat Gain Coefficient