

**From:** [Michael F Sugrue](mailto:Michael.F.Sugrue@energystar.gov)  
**To:** [windows@energystar.gov](mailto:windows@energystar.gov)  
**Subject:** Energy Star Version 7.0 Draft 1 for Windows, Doors, and Skylights Comments  
**Date:** Tuesday, July 13, 2021 4:27:31 PM

---

Dear EnergyStar.Gov:

Thank you for the opportunity to comment on Energy Star Version 7.0 Draft 1. Eventhough many of Winchester's products exceed the numbers you proposed I feel strongly that the drop is too drastic from the current requirements. Therefore, I would recommend .25 U-value and .25 SHGC for North and North Central and .28 U-Value and .24 for Southern Central and Southern.

Please feel free to contact me if you have any questions.

Sincerely,

WINCHESTER INDUSTRIES

Mike

Michael F. Sugrue  
President  
Winchester Industries  
500 Leech Ave, P.O. Box 160  
Saltsburg, PA 15681  
[mfsugrue@winchesterwindows.net](mailto:mfsugrue@winchesterwindows.net)  
PH: 724-639-3551  
Fax: 724-639-8459

Sent from [Mail](#) for Windows 10