

Comment Response Matrix Addendum:
Specific Window Criteria Suggestions

Specific stakeholder recommendations regarding the windows criteria are listed in this addendum. More general comments on the windows criteria ranges proposed in the Framework Document are found on row 63-66 in the main comment response matrix. The EPA response on line 65 addresses the criteria listed below.

Windows Suggestion No. 1	U-Factor	SHGC
Northern		
North-Central		
South-Central		≤ 0.25
Southern		≤ 0.25

Windows Suggestion No. 2	U-Factor	SHGC
Northern		≥ 0.40
North-Central		
South-Central		
Southern		

Windows Suggestion No. 3	U-Factor	SHGC
Northern	≤ 0.30	
North-Central		
South-Central		
Southern		

Windows Suggestion No. 4	U-Factor	SHGC
Northern	≤ 0.20-0.22	
North-Central		
South-Central		
Southern		

Windows Suggestion No. 5	U-Factor	SHGC
Northern	≤ 0.28-0.30	Any
North-Central	≤ 0.30	≤ 0.35-0.40
South-Central	≤ 0.32	≤ 0.25
Southern	≤ 0.40	≤ 0.25

Windows Suggestion No. 6	U-Factor	SHGC
Northern	≤ 0.25	≥ 0.40
North-Central	≤ 0.25	Any
South-Central		
Southern		

Windows Suggestion No. 7	U-Factor	SHGC
Northern	≤ 0.25	≥ 0.32
North-Central	≤ 0.28	Any
South-Central		
Southern		

Windows Suggestion No. 8	U-Factor	SHGC
Northern	≤ 0.28	
North-Central	≤ 0.30	
South-Central		
Southern		≤ 0.25

Windows Suggestion No. 9	U-Factor	SHGC
Northern	≤ 0.25	≥ 0.30
North-Central		≤ 0.40
South-Central		
Southern		

Windows Suggestion No. 10	U-Factor	SHGC
Northern	≤ 0.20	
North-Central		
South-Central		
Southern		

Windows Suggestion No. 11	U-Factor	SHGC
Northern		
North-Central		
South-Central		
Southern	≤ 0.45-0.50	

Windows Suggestion No. 12	U-Factor	SHGC
Northern	≤ 0.25	
North-Central	≤ 0.28	
South-Central		
Southern		

Windows Suggestion No. 13*	U-Factor	SHGC
Northern	≤ 0.20	Any
North-Central	≤ 0.25	Any
Central	≤ 0.28	≤ 0.35
South-Central	≤ 0.32	≤ 0.25
Southern	≤ 0.4	≤ 0.20

*See Comment No. 18