

Email received on June 13, 2010 from Steven Willner.

I strongly support the requirement for outdoor luminaires that reads "Luminaire must deliver 95% of total lumens within the 0°- 85° zone (bilaterally symmetrical). Luminaire must not emit any light above 90°."

Efficiency means putting the light where it is needed, not where it is not needed.

Steven Willner