

Email received on June 9, 2010 from Mike Hansen.

The two things I would comment on are:

- 1) I believe it is worthwhile and essential that *all* exterior luminaires be restricted to have 100% of their light output below the horizontal. There is no reason that a well designed installation can't accommodate this.
- 2) Remove the height restriction (currently 10.5 feet). Many exterior fixtures are mounted higher than this and some of these are the most problematic.

Mike Hansen